

**ADDENDUM NO. 1  
TO THE BID DOCUMENTS**

**Project:** Karen Hornaday Park Campground/Trail Improvements  
**Addendum Issue Date:** August 22, 2014  
**Bid Date:** September 4, 2014 @ 2:00 PM (Thursday)  
**Previous Addenda Issued:** None  
**Issued By:** Carey Meyer  
Public Works Director  
City of Homer  
Homer, AK 99603  
[dnelsen@ci.homer.ak.us](mailto:dnelsen@ci.homer.ak.us)

-----  
Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by one of the following methods:

- (1) By acknowledging receipt of this addendum in the bid submitted.
- (2) By facsimile (fax) or email which will need to include a reference to the project and each of the addendum numbers.

The bid documents require acknowledgement individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid.

-----

The bid documents for the above project are amended as follows (all other terms and condition remain unchanged):

**ITEM 1 - Will a surveyor be required?**

Answer: The City will provide any survey necessary. The City will provide staking of trail alignment and campground space excavation and gravel capping limits.

**ITEM 2 - Can the completion date be extended?**

Answer: The completion date is hereby extended to November 30.

**ITEM 3 - Will the City require material or compaction testing?**

Answer: The Contractor will not be responsible for material or compaction testing. Should the City find it necessary to obtain material sieve analysis or compaction test results, the City will coordinate and pay for these tests.

**ITEM 4 - Does Type III gravel have any crushed gravel component?**

Answer: Below are the gradation and material specifications for “Type III” gravel to be used on this project.

Material shall be 2-inch minus gravel (no required fracture percentage) as specified below:

<u>U.S. Std. Sieve</u>	<u>Cumulative % Passing</u>
Coarse Aggregate	
2”	100
1-1/2”	90-100
1”	70-100
3/4”	60-90
3/8”	45-75
Fine Aggregate	
#4	30-60
#8	22-52
#40	8-30
#200	4-8

Gravel used shall be “dirty” enough to contain sufficient binder to provide for a surface capable of resisting wash-boarding.

**ITEM 5 - To what extent does the vegetation/sod along each side of the campground roads need to be removed?**

Answer: All vegetation/sod growing into and on the existing gravel subgrade surface shall be removed. Some additional vegetation/sod may be required to be removed immediately adjacent to the existing gravel subgrade to provide positive drainage off the road surface.

End Addendum #1