

**ADDENDUM NO. #1**

**Project:** Eric Lane Road and Sewer Improvements  
**Addendum Issue Date:** September 15, 2016  
**Bid Date:** September 22, 2016 @ 2:00 PM (Thursday)  
**Previous Addenda Issued:** None  
**Issued By:** Carey Meyer  
City Engineer - City of Homer  
Homer, AK 99603  
[cmeyer@ci.homer.ak.us](mailto:cmeyer@ci.homer.ak.us)

-----  
Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by one of the following methods:

- (1) By acknowledging receipt of this addendum in the bid submitted (**use addendum acknowledgement form provided in bid documents**).
- (2) By facsimile (fax) or email which will need to include a reference to the project and each of the addendum numbers.

The bid documents require acknowledgement individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may cause the bid to be considered non-responsive.

-----

**ITEM 1** – Bids are due at 2:00 PM, but will be opened and publicly read starting at 2:15 (due to competing bid opening same time).

**ITEM 2** – Are you sure you want the hydrants install so far up the slope?

No, revise plans as follows:

Hydrant at Sta. 14+11.35	Install 26' LT (not 38' LT); back edge of ditch
Hydrant at Sta. 17+15.96	Move to Sta.19+60 and install 26' LT

(both hydrant are 7' bury hydrants)

**ITEM 3** – Don't see top elevations information on sanitary sewer manholes?

See attached plans showing this information (highlighted in yellow).

**ITEM 4** – Do you want anything waterproofing applied to the outside of the manholes?

Yes, see attached revised plans showing application (highlighted in yellow).

END ADDENDUM #1