

ADDENDUM NO. #1

Project: Homer Wastewater Treatment Plant HVAC Rehabilitation
Addendum Issue Date: February 6, 2018
Bid Date: February 22, 2018 @ 2:00 PM (Thursday)
Previous Addenda Issued: None
Issued By: Carey Meyer, P.E.
City Engineer - City of Homer
Homer, AK 99603
cmeyer@ci.homer.ak.us

Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by one of the following methods:

- (1) By acknowledging receipt of this addendum in the bid submitted (**use addendum acknowledgement form provided in bid documents**).
- (2) By facsimile (fax) or email which will need to include a reference to the project and each of the addendum numbers.

The bid documents require acknowledgement individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may cause the bid to be considered non-responsive.

ITEM 1 – Clarification of Duct/Roof Penetrations

Attached is a revised Sheet M300 and M401 showing revisions to the design and the location of the roof penetrations. Sheet M300 shows clarifications to the locations of the southern and center duct penetrations in plan view. Sheet M401 relocates the center duct penetration and increases the height of the goose neck hoods associated with the northern HRV duct. Revisions are clouded.

Also attached is an Existing Roof Plan and a Proposed Roof Plan that provides clarification regarding the locations of existing and proposed roof penetrations; and photos of the existing roof/duct penetrations.

ITEM 2 - What is the make and model of the electrical panel "MCC" and "C"?

MCC is a Square D – Model 5
Panel C is a Square D – Model NQOD

ITEM 3 – Can you provide information about the AIR ELIMINATOR/DIRT SEPARATOR (AS-1)?

Under Miscellaneous Schedules add the following: SPIROTHERM MODEL VDR200FT, 2" PIPE SIZE, AIR VENT, BRASS BODY, COPPER COALESCING MEDIA, DIRT TRAP, DRAIN VALVE, 14.5 LBS.

END ADDENDUM #1

**EXISTING
ROOF PLAN VIEW**













