

ADDENDUM NO. #2

Project: Homer Ramp 2 Restroom Replacement
Addendum Issue Date: June 20, 2018
Bid Date: June 28, 2018 @ 2:00 PM (Thursday)
Previous Addenda Issued: #1
Issued By: Carey Meyer, P.E.
City Engineer - City of Homer
Homer, AK 99603
cmeyer@ci.homer.ak.us
(907) 235-3170 (office) (907) 399-7232 (cell)

Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by one of the following methods:

- (1) By acknowledging receipt of this addendum in the bid submitted (**use addendum acknowledgement form provided in bid documents**).
- (2) By facsimile (fax) or email which will need to include a reference to the project and each of the addendum numbers.

The bid documents require acknowledgement individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may cause the bid to be considered non-responsive.

ITEM 1 – Detail 1 on S7.2 shows the roof assembly with self-adhering underlay but the spec 07412.3.2 A. calls out 30# paper. Please clarify.

Provide “Grace Ice and Water Shield” (or owner approved substitution) self-adhered roofing underlayment installed on the entire roof in accordance with manufacturers recommendations. No 30# paper required.

ITEM 2 - Specification 10210 - Toilet Compartments, Section 1.6, E

Replace ~~**2. Smoke-Developed Index: 450.**~~
With **2. Smoke-Developed Index: 0-450.**

ITEM 3 – Regarding the HDPE partitions, would Scranton be approved to submit on in lieu of Bradley?

Yes, Scranton Products is an approved substitute manufacturer for toilet compartments.

END ADDENDUM #2