

**ADDENDUM NO. 2  
TO THE BID DOCUMENTS**

**Project:** Deep Water Dock Uplands Improvements 2016  
**Addendum Issue Date:** February 11, 2016  
**Bid Date:** February 18, 2016 @ 2:00 PM (Thursday)  
**Previous Addenda Issued:** None  
**Issued By:** Carey Meyer  
City Engineer  
City of Homer  
Homer, AK 99603  
[cmeyer@ci.homer.ak.us](mailto:cmeyer@ci.homer.ak.us)

-----  
Bidders must acknowledge receipt of this addendum prior to the date set for bid opening by one of the following methods:

- (1) By acknowledging receipt of this addendum in the bid submitted (**use addendum acknowledgement form provided in bid documents**).
- (2) By facsimile (fax) or email which will need to include a reference to the project and each of the addendum numbers.

The bid documents require acknowledgement **individually** of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may cause the bid to be considered non-responsive.

-----

The bid documents for the above project are amended as follows (all other terms and condition remain unchanged):

**ITEM 1 – Revised Bid Schedule**

Bidders can manually revise the bid schedule as shown below.

C- 1	904	Luminaire Pole Foundation	per EA	9 8
C- 2	905	Luminaire Pole, 2-Arm, Fixed Base, 39 Ft.	per EA	9 8

**ITEM 2 – Revised Lighting Plan (Sheet E1.2)**

Included in this addendum is a revised Sheet E1.2, reflecting change in lighting and camera locations. The sheet reflects the installation of 8 poles along the south side of the storage/laydown area, rather than the 9 poles, as were previously shown, along the northern side. Camera locations also revised. Please refer to the revision note, on the drawing, for instructions concerning coordination of alpha numeric designators through the package.

**ITEM 3 – Fiber Termination Clarification (Revision to Note 7, Sheet E1.6)**

Revise note 7 to read:

PROVIDE TERMINATION OF ALL FIBERS, AFL FUSECONNECT FUSION-SPLICED FIELD-TERMINATED OR OWNER-APPROVED EQUAL, HIGH-PERFORMANCE, SINGLE-MODE, TYPE-SC, NO-EPOXY/NO-POLISH, UPC, SINGLE MODE CONNECTOR HOUSINGS SHALL BE THE COLOR BLUE; COORDINATE CONNECTOR BOOT TYPE AND SIZE WITH THE PROVIDED CABLE; UNICAM CONNECTORS ARE NOT ACCEPTABLE TO THE OWNER AND SHALL NOT BE USED.

**ITEM 4 – Oral, Telephonic, and Facsimile Bids**

Oral, telephonic, and facsimile Bids will not be considered. Modification by facsimile, of Bids already submitted, will be considered if received prior to the time fixed in the Invitation to Bid. Facsimile modifications shall indicate the amount of the revised Bid and shall be signed by a properly authorized agent, officer, or partner. Fax bid modification to the City Clerk (907) 235-3143

**ITEM 5 – Will the Contractor be responsible for Homer Electric Association (HEA) fees?**

All fees charged by HEA to provide electric service to the Contractor provided load center (shown on Sheet E1.4) will be paid for by the City. The junction box near the proposed load center is not capable of supplying secondary voltage. It will require HEA to install a transformer. The cost of installing this new transformer is the responsibility of the City.

**ITEM 6 – Can we use PVC conduit in lieu of HDPE for electrical UG runs?**

No.

End Addendum #2